

Micro-Measurements **EMEME**

Principal Stress Separation



DESCRIPTION

To separate the principal strains located in areas other than at free boundaries, an additional measurement is required which can be obtained by two different methods. One method employs the Slitting Technique, while the other is based on the use of a PhotoStress Separator Gage. Because of its ease of application and interpretation, the Separator Gage is usually preferred. However, when

working with the medium- and low-modulus class of PhotoStress materials, the Separator Gage is not applicable.

PhotoStress Separator Gage



The PhotoStress Separator Gage is a unique electrical resistance gage, designed and produced by Micro-Measurements, that measures the sum of the principal strains. This data, when coupled with the measured

difference of principal strains made with the LF/Z-2 PhotoStress Plus provides the separate principal strain values.

The PhotoStress Separator Gage has special design features for ease of use and optimum performance in PhotoStress applications. Pre-attached leadwires are provided to avoid soldering problems after the gage is bonded to the photoelastic coating, and the gage is polyimide-encapsulated to eliminate the need for a protective coating in most cases. Gages are supplied three-to-apackage, and are offered in two self-temperature-compensation types: 06 and 13, for use on steel and aluminum alloys, respectively. The Separator Gage can be used on photoelastic coating material types PS-1, PS-8, PL-1, and PL-8.

RESISTANCE	MATRIX SIZE	DIMENSIONS			
		GAGE LENGTH	OVERALL LENGTH	GRID WIDTH	OVERALL WIDTH
200Ω ± 15%	0.30in L x 0.20in W	0.063in	0.255in	0.057in	0.160in
	7.6mm L x 5.1mm W	1.60mm	6.48mm	1.45mm	4.06mm
$1000\Omega \pm 0.5\%^*$	0.30in L x 0.20in W	0.063in	0.255in	0.057in	0.160in
	7.6mm L x 5.1mm W	1.60mm	6.48mm	1.45mm	4.06mm

Document Number: 11254 Revision: 25-Feb-10

EMEME Micro-Measurements



Principal Stress Separation

Model 330 Interface Module



Separator Gages must be used with a specially designed interface module in conjunction with the Measurements Group P-3 Strain Indicator. The Model 330 Interface Module is a four-channel switch-and-balance unit with precision resistive circuits for reducing gage excitation voltage to minimize self-heating effects, supplying bridge-completion for the 200-ohm Separator Gage, and attenuating the gage output so that the P-3 Strain Indicator reads out in units of 10 microstrain. Provided with the Model 330 are four specially

configured connecting cables for quick and convenient solderless connections between the Separator Gage leadwires and the Interface Module.



Connecting cable

The 6-foot (1.8m) cable incorporates gold-plated push/clamp binding posts to assure negligible contact resistance at leadwire connections.

* The 1000 Ω separator gage can be connected directly to the P3 strain indicator without the 330 Module.



Legal Disclaimer Notice

Vishay Precision Group, Inc.

Disclaimer

ALL PRODUCTS. PRODUCT SPECIFICATIONS AND DATA ARE SUBJECT TO CHANGE WITHOUT NOTICE.

Vishay Precision Group, Inc., its affiliates, agents, and employees, and all persons acting on its or their behalf (collectively, "VPG"), disclaim any and all liability for any errors, inaccuracies or incompleteness contained herein or in any other disclosure relating to any product.

The product specifications do not expand or otherwise modify VPG's terms and conditions of purchase, including but not limited to, the warranty expressed therein.

VPG makes no warranty, representation or guarantee other than as set forth in the terms and conditions of purchase. To the maximum extent permitted by applicable law, VPG disclaims (i) any and all liability arising out of the application or use of any product, (ii) any and all liability, including without limitation special, consequential or incidental damages, and (iii) any and all implied warranties, including warranties of fitness for particular purpose, non-infringement and merchantability.

Information provided in datasheets and/or specifications may vary from actual results in different applications and performance may vary over time. Statements regarding the suitability of products for certain types of applications are based on VPG's knowledge of typical requirements that are often placed on VPG products. It is the customer's responsibility to validate that a particular product with the properties described in the product specification is suitable for use in a particular application. You should ensure you have the current version of the relevant information by contacting VPG prior to performing installation or use of the product, such as on our website at vpgsensors.com.

No license, express, implied, or otherwise, to any intellectual property rights is granted by this document, or by any conduct of VPG.

The products shown herein are not designed for use in life-saving or life-sustaining applications unless otherwise expressly indicated. Customers using or selling VPG products not expressly indicated for use in such applications do so entirely at their own risk and agree to fully indemnify VPG for any damages arising or resulting from such use or sale. Please contact authorized VPG personnel to obtain written terms and conditions regarding products designed for such applications.

Product names and markings noted herein may be trademarks of their respective owners.

Copyright Vishay Precision Group, Inc., 2014. All rights reserved.

Document No.: 63999 Revision: 15-Jul-2014